

ARCHIBUS	Problem Location	Date Work Requested	Work Description	Comments/ status
11680002	ALDERMAN TOMMY PATTON MEMORIAL PARK - BOWLING PAVILION	27/12/2010	Callout 27.12.10 to repair leak in ceiling	Works Commencing 11th Jan 2011- scaffold required
11679964	ANDERSONSTOWN LEISURE CENTRE	29/12/2010	Investigate fire panel producing a lot of corrupt data	Complete
11679997	BARNETT DEMESNE - MALONE HOUSE	26/12/2010	CALLOUT 26.12.10 FOR BURST PIPE	Complete
11680000	BARNETT DEMESNE - MALONE HOUSE	27/12/2010	Callout 27.12.10 to repair leak from ceiling	Follow up repairs Required' ceiling damaged, lead gully needs checked and repaint'
11680108	BARNETT DEMESNE - MALONE HOUSE	03/01/2011	Call out - Water leaking in Ladies WC	Completed
11680007	BEECHMOUNT LEISURE CENTRE	27/12/2010	Callout for leak in roof	Condensation/ damp within building causing smoke detectors to fault.
11680035	BELFAST ZOO - B SECTION	29/12/2010	callout 28.12.10 for blocked drains	Completed
11680027	BELFAST ZOO - C SECTION	30/12/2010	Reset boiler for visitors centre - no power	Completed
11680073	BELFAST ZOO - C SECTION	31/12/2010	Clear blocked drains in zebra den in elephant house	Completed
11680034	BELFAST ZOO - FRIENDS ROOM	28/12/2010	Callout 28.12.10 for burst pipes	Follow up repairs Required
11680025	BELFAST ZOO - OLD ZOO BUILDINGS	30/12/2010	No electrics at old zoo	Follow up Repairs Required- Temporary fix, and animals moved to accommodate cable
11680071	BELFAST ZOO - OLD ZOO BUILDINGS	31/12/2010	No electrics in old Zoo	As above, same problem- tripped twice
11680017	BLANCHFLOWER PLAYING FIELDS - CHANGING ACCOMODATION	30/12/2010	Callout 28.12.10 for burst pipe	Follow up Repairs Required- Extensive damage to heating system - new heating system
11679961	BLANCHFLOWER PLAYING FIELDS - SOCIAL CANTEEN	29/12/2010	repair burst pipes after callout	procured, awaiting update from contractor & phoenix gas for programme.
11679990	BLYTHEFIELD -GROUNDS	29/12/2010	Repair leak from pipe in roof	Follow up Repairs Required- Isolated but not repaired, substantial damage caused to
11679976	BOTANIC GARDENS - GATE LODGE	29/12/2010	Blocked sink in kitchen area	Isolated, made safe- Follow up required
11680003	BOTANIC GARDENS - TROPICAL RAVINE	27/12/2010	Callout 27.12.10 for burst pipe	Completed
11679984	BOUCHER RD PLAYING FIELDS - CHANGING ACCOMMODATION	29/12/2010	Repair leak in plant room	(Requires new vent pipe fitted to boiler 2" galv on outside of boiler house and lagging renewed on both boiler vents)
11680020	CITY OF BELFAST PLAYING FIELDS - CHANGING ACCOMMODATION	30/12/2010	Repair burst pipe in public toilets	Isolated, made safe- Follow up required
11680028	DIXON PARK PLAYING FIELDS - CHANGING ACCOMMODATION	30/12/2010	Repair burst pipe	Follow up repairs Required
11679956	FALLS PARK - BOWLING/CAMOGIE PAVILION	29/12/2010	Heating not working	Completed
	GROVE BOWLING PAVILION	22/12/2010	Bust pipes in boiler house and roof space	Complete apart from bib tap in boiler house to be replaced and re-piped
11679887	GROVE FOOTBALL PAVILLION		No heat bust pipes	Severe damage in Boiler house.
11680012	KING GEORGE V PLAYING FIELDS - CHANGING ACCOMMODATION	26/12/2010	CALLOUT 26.12.10 FOR BURST PIPE IN BOILER ROOM ZONE 12	Follow up repairs Required - wjm
11680021	LOUGHSIDE - RECREATION CENTRE	30/12/2010	No heating	Completed
11680080	LOUGHSIDE - RECREATION CENTRE	31/12/2010	Flooding in changing room 6	Completed
11680078	MARY PETERS TRACK - STORE BUILDING	31/12/2010	Repair burst pipe in gardeners pavilion	Follow up repairs Required - Burst meter
11679929	MUSGRAVE - BOWLING PAVILLION	23/12/2010	No hot water	Pressure valve blew off water heater- requires follow up
11680030	ORANGEFIELD PLAYING FIELDS - BOWLING PAVILION	30/12/2010	Repair burst pipe	Completed
11680024	ORANGEFIELD PLAYING FIELDS - CHANGING ACCOMMODATION	30/12/2010	Repair burst water pipe	Follow up repairs Required
11680082	ROSELAWN CEMETERY - OFFICE	31/12/2010	Repair front lights out in public area	Completed
11679992	ROSELAWN CEMETERY - SERVICE YARD	29/12/2010	Repair burst pipe in store	Completed
11680016	ROSELAWN CEMETERY - SERVICE YARD	29/12/2010	Callout 28.12.10 for burst pipe in Service yard	Completed
11680146	ROSELAWN CEMETERY - GROUNDS	05/01/2011	2 Bursts in section P	
11679967	ROSELAWN CREMATORIUM	29/12/2010	Repair electric supply to cremator it is tripping the water pump	Repaired- follow up re-design and flood alarms required
11679970	ROSELAWN CREMATORIUM	29/12/2010	Lights out in outer church corridor	Completed
11679991	ROSELAWN CREMATORIUM	29/12/2010	Burst heating pipes in coffee shop roof	Completed
11679999	ROSELAWN CREMATORIUM	27/12/2010	CALLOUT 27.12.10 TO REPAIR FAULT WITH PORTABLE PUMP	Completed.
11679966	SHANKILL LEISURE CENTRE	29/12/2010	Repair burst heating batteries on pool ventilation and heating units	Follow up Repairs Required- One heater battery temp repaired, and one unrepairable.
11680029	SHANKILL LEISURE CENTRE	30/12/2010	Cannot set intruder alarm	Completed
11680042	SHANKILL LEISURE CENTRE	29/12/2010	Callout 29.12.10 for intruder alarm not setting	Completed
11680093	SHANKILL LEISURE CENTRE	26/12/2010	Heating Panel Burst	
11680032	SHORE RD PLAYING FIELDS - CHANGING ACCOMMODATION	30/12/2010	Repair burst pipe at changing	Isolated, made safe- Follow up required
11679965	SIR THOMAS & LADY DIXON PARK - SERVICE YARD	31/12/2010	Oil heating system needs bled	Completed
11680015	SIR THOMAS & LADY DIXON PARK - SERVICE YARD	28/12/2010	CALLOUT 28.12.10 BURST PIPE	Completed
11680009	SIR THOMAS & LADY DIXON PARK - WILMONT HOUSE	27/12/2010	CALLOUT 27.12.10 FOR MAJOR FLOODING IN BASEMENT	Isolated, made safe- Follow up required
11680040	SIR THOMAS & LADY DIXON PARK - WILMONT HOUSE	29/12/2010	Callout 29.12.10 for power failure	Isolated, made safe- Follow up required
11679971	STRANGFORD AVE PLAYING FIELDS - CHANGING ACCOMMODATION	29/12/2010	Repair burst pipe in old pavilion	Isolated, made safe- Follow up required
11680036	SUFFOLK COMMUNITY CENTRE	30/12/2010	Callout 28.12.10 for burst pipes	operational - awaiting non return valve- on order
11680013	SUFFOLK PLAYING FIELDS - CHANGING ACCOMMODATION	26/12/2010	Callout 26.12.10 for burst pipe	Completed
11680076	SUFFOLK PLAYING FIELDS - CHANGING ACCOMMODATION	31/12/2010	Callout 30.12.10 for burst pipe	Completed
11680022	VICTORIA PARK - CHANGING ACCOMMODATION	30/12/2010	Repair burst pipe	Isolated, made safe- Follow up required
11680044	VICTORIA PARK - CHANGING ACCOMMODATION	30/12/2010	Repairs to fire alarm keeps going off	Completed
11680106	WATERWORKS - SOCIAL PAVILLION	05/01/2011	Call out 03/01/2011- Repair Burst pipe	Completed
11680074	WEDDERBURN PARK - CHANGING ACCOMMODATION	31/12/2010	Callout 31.12.10 for fault in system	Completed - Linked to leaks
11680075	WEDDERBURN PARK - CHANGING ACCOMMODATION	31/12/2010	Callout 31.12.10 for burst pipe in ceiling	Follow up repairs Required - 3 leaks in changing, bowls & Bothy
11680077	WEDDERBURN PARK - CHANGING ACCOMMODATION	31/12/2010	Check intruder alarm still making buzzing noise	Isolated, made safe- Follow up required
	WOODLANDS playing fields Pav		Burst in boiler House	Isolated, made safe- Follow up required
11679915	WHITEROCK LEISURE CENTRE	23/12/2010	Repair roof leak at reception	Isolated, made safe- Follow up required on CHP unit- currently off.
11679923	WHITEROCK LEISURE CENTRE	23/12/2010	Check & make safe electrics after burst pipe	Completed
11679988	WOODVALE PARK - BOWLING PAVILION/SHELTER	29/12/2010	Reset fire/intruder alarm needs reset keeps going off	Completed
11680039	WOODVALE PARK - FOOTBALL PAVILION	29/12/2010	Callout 29.12.10 for burst pipes	Completed
11680018	WOODVALE PARK - SERVICE YARD	31/12/2010	Callout 28.12.10 for burst pipe	Completed