

Minimum Standards Checklist for the installation of an Oil boiler

Applicant Name: «apname»
Property Address: «paddr2»
Affordable Warmth Scheme Reference: « refno »

Is the new boiler at the above address in accordance with the requirements set out below:

1. Is the new boiler in accordance with the current Building Regulations and the Heating Compliance Guide ☐
2. Has a new bunded oil tank been fitted in accordance with BS 5410 ☐
3. How many fire barriers are fitted
4. Has a remote fire valve been fitted in accordance with BS 5410
5. Has pressure relief valve been fitted and piped to low level
6. Are the following time and temperature controls on the hot water and space heating:
 - a. 2 Channel Time Clock ☐
 - b. 2 no. 2 port motorised valves ☐
 - c. Hot Water Cylinder Thermostat ☐
 - d. Room Thermostat ☐
 - e. TRVs on all radiators (except the bathroom and the room where the thermostat has been fitted ☐
 - f. Has the boiler interlock has been achieved ☐
 - g. If required under the Building Regulations, has Carbon Monoxide detector been provided ☐

Signature		Date
-----------	--	------

